

NOTICE OF DETERMINATION

CLERK OF THE BOARD OF SUPERVISORS
2024 MAY 14 AM 11:09
SANTA ANA DEL CHINO COUNTY
CALIFORNIA

To: San Bernardino County
Clerk of the Board
385 North Arrowhead Avenue
San Bernardino, CA 92415

From: Inland Empire Utilities Agency
6075 Kimball Avenue
Chino, CA 91708

and
Office of Planning and Research
State Clearinghouse
1400 Tenth Street
Sacramento, CA 95814

DATE FILED & POSTED

Posted On: 5-14-24

Removed On: 6-20-24

Receipt No: 36-05142024-355

Subject: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

Addendum No. 2 to the Facilities Master Plan Program Environmental Impact Report for the
RP-5 Expansion Implementation Project

Project Title

SCH#2016061064
State Clearinghouse Number

Mr. Pietro Cambiaso
Lead Agency Contact Person

(909) 993-1639
Telephone Number

Project Location

Regional Plant Number 5 (RP-5) is one of IEUA's regional wastewater reclamation facilities. RP-5 is located south of Kimball Avenue between El Prado Road and Mountain Avenue. The project area is mapped within the un-sectioned portion of the Santa Ana del Chino land grant lying within Township 2 South, Range 8 West on the USGS – Prado Dam Quadrangle, 7.5 Minute Series topographic map, Latitude 33°58'0.3" North and Longitude 117°40'20" West.

Project Description

Addendum is being compiled to address the following issues related to the RP-5 Expansion Offsite Facilities Projects. These projects were not included in the PEIR, and in order to acquire funding to implement these four Offsite Projects, an Addendum has been selected to comply with the California Environmental Quality Act (CEQA). These four projects include:

1. Butterfield Ranch Pump Station (lift station): An existing pump station where two actions will be carried out. Internal to the existing building, the existing pumps will be upsized and the existing Motor Control Center (MCC) will be replaced by a new MCC. The purpose of the modified lift station is to pump wastewater to RP-5 i. There will be no new ground disturbance at the site, just modifications to the building interior. With no new ground disturbance, there is no potential to adversely impact any biological or cultural resources at the project site. In this analysis this facility will be referred to as Site 1.
2. Mountain Avenue Pump Station (lift station): This project will construct a new pump station (lift station) adjacent to Mountain Avenue, across from Bickmore Avenue where it intersects Mountain Avenue at IEUA's Solids Handling Facility site. This lift station will connect to the Butterfield Dual Force Main on Mountain Avenue and will help convey wastewater to the modified RP-5 Water Recycling Plant for treatment. The new lift station will operate with two new pumps with a total of 560-gallons per minute (gpm) capacity. The new pump station will be approximately 30 feet by 10 feet, which includes the valve/meter vault and the lift station pumps. The lift station depth (i.e., pump wet well) is approximately 30 feet deep. Electricity will be delivered by a new connection to local Southern California Edison (SCE) power box P5545120. The new pump station will be installed on highly disturbed ground adjacent to Mountain Avenue and on the disturbed IEUA Solids Handling Facility site. Limited biological and cultural resources can occur on this site. In this analysis this facility will be referred to as Site 2.

Notice of Determination, page 2 of 2

- 3. Butterfield Force Mains: Dual force mains will be installed from El Prado Road to Kimball Avenue within the Mountain Avenue right-of-way (ROW). Both force mains are 8 inches to 14-inches diameter HDPE DR 11 pipelines; Line A is a total of approximately 6,175 linear feet, and Line B is a total of 6,200 linear feet. These two mains are needed to convey wastewater flows generated outside of Prado Basin. Primary flow will be from the Butterfield Ranch Pump Station. Lesser flows from the modified RP-2 Lift Station and from the Mountain Avenue Pump Station will be conveyed as well. These force mains will terminate at the main trunk sewer in Kimball Avenue for delivery to RP--5. The two force mains will be installed within the disturbed Mountain Avenue ROW (shoulder to shoulder) where the roadway has been graded, filled, compacted and/or paved. In this analysis this facility will be referred to as Site 3.
- 4. RP-2 Lift Station: The existing lift station at RP-2 will be modified to receive flows generated within the Prado Basin from El Prado Golf Course and a private lift station on Pine Avenue. This pump station will deliver flows to the Butterfield Force Mains (discussed under item 3). The RP-2 Lift Station modifications include replacing the existing pumps at the RP-2 pump station with two smaller pumps, construction of an elevated platform for all electrical gear (to place the electrical equipment above the local 100-year flood level) and a standby generator. The work proposed for RP-2 is in response to the U.S. Army Corps raising the height of Prado Dam Spillway and the expanded zone of inundation in the Prado Basin. In this analysis this facility will be referred to as Site 4.

This is to advise that the Inland Empire Utilities Agency has approved the above described project on Lead Agency Responsible Agency

02/21/2024 and has made the following determination regarding the above described project:
(Date)

- 1. The project [will will not] have a significant effect on the environment.
- 2. An Addendum No. 2 to the previously adopted Facilities Master Plan Program Environmental Impact Report (#2016061064) was prepared for this project pursuant to the provisions of CEQA.
- 3. Mitigation measures [were were not] made a condition of the approval of this project.
- 4. Mitigation measures from the original PEIR will be implemented in accordance with the approval of the project.
- 5. A Statement of Overriding Considerations { was was not} adopted for this project.
- 6. Findings [were were not] made pursuant to the provisions of CEQA.

This is to certify that the Environmental Impact Report and record of project approval is available to the general public at:

Inland Empire Utilities Agency located at 6075 Kimball Avenue, Chino, CA 91708

Philip Ruediger Manager of Compliance and Sustainability 5/14/2024
Signature Title Date

CLERK OF THE BOARD OF SUPERVISORS
 2024 MAY 14 AM 11:10
 SAN BERNARDINO COUNTY CALIFORNIA

COPY

Notice of Determination

CLERK OF THE BOARD OF SUPERVISORS

Appendix D

2017 MAR 17 PM 2:39

TO:

Office of Planning and Research
For U.S. Mail:
P.O. Box 3044
Sacramento, CA 95812-3044

COUNTY OF SAN BERNARDINO CALIFORNIA

Street Address:
1400 Tenth Street
Sacramento, CA 95814

Public Agency: Inland Empire Utilities Agency

Address: 6075 Kimball Avenue
Chino, CA 91708

Contact: Pietro Cambiaso

Phone: (909) 993-1639

Lead Agency (if different from above):

County Clerk
County of: San Bernardino
Address: 385 N. Arrowhead Avenue - San Bernardino, CA 92415

Subject: Filing of Notice of Determination in compliance with Section 21108 or 21152 of the Public Resources Code.

State Clearinghouse Number (if submitted to State Clearinghouse): 2016061064

Project Title: IEUA Facilities Master Plans

Project Location (include county): Various cities in San Bernardino County

Project Description: The FMP encompasses six of IEUA's master planning efforts including the Asset Management Plan, the Recycled Water Program Strategy, the Amendment to the 2010 Recharge Master Plan Update, the Wastewater Facilities Master Plan Update Report, the Integrated Water Resources Plan, and the Energy Management Plan. The activities that would be implemented within these individual Facilities Master Plans would provide for future wastewater treatment, biosolids handling, and recycled water production for the IEUA service area.

This is to advise that the Inland Empire Utilities Agency has approved the above described project on (X Lead Agency or Responsible Agency)

and has made the following determinations regarding the above described projects. (Date)

- 1. The project [X will] [] will not have a significant effect on the environment.
2. [X] An Environmental Impact Report was prepared for this project pursuant to the provisions of CEQA. [] A Negative Declaration was prepared for this project pursuant to the provisions of CEQA.
3. Mitigation measures [X] were [] were not made a condition of the approval of the project.
4. A mitigation reporting or monitoring plan [X] was [] was not adopted for this project.
5. A statement of Overriding Considerations [X] was [] was not adopted for this project.
6. Findings [X] were [] were not made pursuant to the provisions of CEQA.

This is to certify that the final EIR with comments and responses and record of project approval, or the Negative Declaration, is available to the General Public at:

IEUA Headquarters, 6075 Kimball Avenue, Building A, Chino, CA 91708

Signature (Public Agency)

Title: General Manager

Date: 3/15/17

Date Received Filing at OPR:

FILED / POSTED

County of Riverside
Peter Aldana
Assessor-County Clerk-Recorder

E-201700307
03/20/2017 08:19 AM Fee: \$ 50.00
Page 1 of 1

Governor's Office of Planning & Research

DATE FILED & POSTED

Posted On: 03/17/17

Removed On: 04/29/17

Receipt No: 36-031717-156

MAR 20 2017

Removed: By: Deputy



STATE CLEARINGHOUSE

SAN BERNARDINO COUNTY CALIFORNIA

2024 MAY 14 AM 11:10

CLERK OF THE BOARD OF SUPERVISORS

