NOTICE OF INTENT TO ADOPT A MITIGATED NEGATIVE DECLARATION

To:

Office of Planning & Research

and

San Bernardino County
Clerk of the Board of Supervisors

State Clearinghouse 1400 Tenth Street

385 N. Arrowhead Avenue, 2nd Floor

San Bernardino, CA 92415

Sacramento, CA 95814

From: Running Springs Water District (RSWD)

31242 Hilltop Blvd. (POB 2206) Running Springs, CA 92382

Project Title:

ROWCO Reservoirs & Booster Replacement Project

SCH Number:

To be assigned

Project Location:

The existing ROWCO reservoirs site is located near Old Highway 18 South between Hollymont Drive and All View Drive in the community of Running Springs. The project site encompasses approximately 87,000 square feet (sf), or about 2.0 acres. The site is located on the Keller Peak 7.5 Minute Series USGS Topographic Quadrangle Map in Section 31, Township 2 North, Range 2 West, SBBM. Specific geodetic location is Latitude 34°12'53" North, and

Longitude 117°07'30 West.

Project Description:

The Project consists of the installation and operation of a new 300,000-gallon welded steel, potable water storage reservoir that will replace the two existing 100,000-gallon bolted steel reservoirs, estimated to be 14 feet diameter and 20 feet height. The new 300,000-gallon steel tank that will be approximately 25-feet in height and 46-feet in diameter. The project site will be re-graded with no major change in the base elevation of about 6,298 feet amsl. About 40 cubic yards (CY) will be cut from the site and removed to a District storage location. Additionally, the portion of the existing access road located within the project site will be improved. The new welded steel tank will maintain about four feet of freeboard to protect the reservoir from sloshing impacts during an earthquake.

The proposed foundation system will be a reinforced concrete ring wall foundation system. Maximum foundation loads are anticipated at 3,500 pounds per linear foot (plf) for continuous (ring wall) foundation and up to 80 kilo-pounds (kips) for isolated pad foundations are anticipated. Associated site improvements will consist of new inlet/outlet piping, overflow and drain piping, installing water level monitoring equipment, new site pavement improvements, block walls and/or chain-link fencing as needed to control potential trespass.

CLERK OF THE BOARD

Received on: 07-01-24

Remove on: 08-02-24

BOARD OF SUPERVISOR

Notice of Intent Page 2

Proje	ect Sponsor(s):	Running Springs Water Dist	rict		
	The Initial Study shows that there is no substantial evidence that the project may have a significant effect on the environment.				
	 The Initial Study identified potentially significant effects but: (1) Revisions in the project plans or proposal made or agreed to by the applicant before this proposed Negative Declaration was released for public review would avoid the effects or mitigate the effects to a point where clearly no significant effects would occur; and, 				
		substantial evidence before th ffect on the environment.	e agency that the proje	ct as revised may have a	
A copy of the Initial Study and all other material which constitutes the record of proceedings upon which RSWD based its decision to adopt this Mitigated Negative Declaration may be obtained online at https://www.runningspringswaterdistrict.com/ and in person at:					
Running Springs Water District 31242 Hilltop Boulevard (PO Box 2206) Running Springs, CA 92382 POC: Ryan Gross, General Manager Tel: (909) 867-2766 Email: rgross@runningspringswd.com					
during on the	g the review period	Negative Declaration will be which begins on July 3, 202 d be submitted to Mr. Ryan G 24 by 5:00 PM .	4 and ends on August	1, 2024. Written comments	
	Pall	Genera	al Manager	6/27/2024	
Signa	ture	Title		Date	
Date	Oate received for filing and posting Clerk of the Board of Supervisors OPR				

2024 JUL - I PM 2: 30
SAN BERNARDINO COUNTY